

地址：山东省烟台市高新区科技大道5号
Address: No. 5, Science and Technology
Avenue, High Tech Zone, Yantai, Shandong
邮编 (P. C.): 264000
电话: 240000102248 4062, 3064051



中国认可
国际互认
检测
TESTING
CNAS L0639

编号: 37030007262100756

日期: 2026-06-26

第 1 页 共 3 页

委托人: 烟台市蓬莱区盛润供水有限公司

联系方式: 蓬莱区南关路 151 号

样品名称: 烟台市蓬莱区盛润供水有限公司出厂水

样品数量重量: 10.5L

样品标记: N/M

样品状态: 液态, 包装完好

检测地点: 烟台海关技术中心(高新区科技大道5号)

收样日期: 2026-06-10

检测日期: 2026-06-10 至 2026-06-26

检验结果:

样品编号	项目名称	检测结果	结果单位	检测方法	判定结论	授权签字人
2621007560001	隐孢子虫	< 1	个/10L	GB/T 5750.12-2023(9.1)	合格	鲁闽
2621007560001	贾第鞭毛虫	< 1	个/10L	GB/T 5750.12-2023(8.1)	合格	鲁闽
2621007560001	大肠埃希氏菌	0	CFU/100mL	GB/T 5750.12-2023(7.2)	合格	鲁闽
2621007560001	总大肠菌群	0	CFU/100mL	GB/T 5750.12-2023(5.2)	合格	鲁闽
2621007560001	菌落总数	3	CFU/mL	GB/T 5750.12-2023(4.1)	合格	鲁闽
2621007560001	汞	<0.07	ug/L	GB/T 5750.6-2023 11.4	合格	曹鹏
2621007560001	钠	28.1	mg/L	GB/T 5750.6-2023 25.4	合格	曹鹏
2621007560001	铁	1.17	ug/L	GB/T 5750.6-2023 5.4	合格	曹鹏
2621007560001	铬(六价)	<0.004	mg/L	GB/T 5750.6-2023(13.1)	合格	曹鹏
2621007560001	环氧氯丙烷	<0.1	ug/L	GB/T 5750.8-2023(20.1)	合格	曹鹏
2621007560001	五氯酚	<0.0005	mg/L	GB/T 5750.9-2023(24.4)	合格	曹鹏
2621007560001	灭草松	<0.0005	mg/L	GB/T 5750.9-2023(15.2)	合格	曹鹏
2621007560001	硒	0.11	ug/L	GB/T 5750.6-2023 10.4	合格	曹鹏
2621007560001	铅	<0.07	ug/L	GB/T 5750.6-2023 14.3	合格	曹鹏
2621007560001	臭氧	<0.01	mg/L	GB/T 5750.11-2023(9.2)	合格	曹鹏
2621007560001	砷	0.64	ug/L	GB/T 5750.6-2023 9.4	合格	曹鹏
2621007560001	总硬度(以CaCO ₃ 计)	171.9	mg/L	GB/T 5750.4-2023(10.1)	合格	曹鹏
2621007560001	1,2-二氯乙烷	<20.0	ug/L	GB/T 5750.8-2023(5.2)	合格	曹鹏
2621007560001	莠去津	<0.0005	mg/L	GB/T 5750.9-2023(20.2)	合格	曹鹏
2621007560001	1,4-二氯苯	<10.0	ug/L	GB/T 5750.8-2023(29.2)	合格	曹鹏
2621007560001	七氯	<0.4	ug/L	GB/T 5750.9-2023(22.2)	合格	曹鹏
2621007560001	2,4-滴	<0.0005	mg/L	GB/T 5750.9-2023(16.2)	合格	曹鹏
2621007560001	亚氯酸盐	<2.4	ug/L	GB/T 5750.10-2023(20.2)	合格	曹鹏
2621007560001	挥发酚类(以苯酚计)	<0.002	mg/L	GB/T 5750.4-2023(12.1)	合格	曹鹏
2621007560001	铜	0.49	ug/L	GB/T 5750.6-2023 7.6	合格	曹鹏
2621007560001	氨(以N计)	<0.02	mg/L	GB/T 5750.5-2023(11.1)	合格	曹鹏
2621007560001	硫酸盐	44.22	mg/L	GB/T 5750.5-2023(4.2)	合格	曹鹏
2621007560001	氰化物	<0.002	mg/L	GB/T 5750.5-2023(7.2)	合格	曹鹏
2621007560001	苯并(a)芘	<0.005	ug/L	GB/T 5750.8-2023(12.1)	合格	曹鹏
2621007560001	氰化物	0.16	mg/L	GB/T 5750.5-2023(6.2)	合格	曹鹏
2621007560001	邻苯二甲酸二(2-乙基己基)酯	<0.4	ug/L	GB/T 5750.8-2023(15.1)	合格	曹鹏
2621007560001	镍	0.20	ug/L	GB/T 5750.6-2023 18.3	合格	曹鹏
2621007560001	色度(铂钴色)	<5	度	GB/T 5750.4-2023(4.1)	合格	曹鹏

1. 我们已尽所知所能实施上述检验, 不能因签发本报告而免除有关各方根据合同和法律所承担的责任和义务。All inspection are carried out conscientiously to the best of our knowledge and ability. This report does not in any respect absolve the other related parties from his contractual and legal obligation.
2. 一般情况, 检验结果仅对申请人所送样品负责, 未经本实验室书面同意, 不得部分复制报告。The results shown in this test report refer only to the sample(s) tested unless otherwise stated. Without the prior written approval from the testing laboratory, the report shall not be reproduced except in full.
3. 本报告未经报告签发人签字或盖章无效。The report is invalid unless it is signed by the report issuer and with a special stamp for inspection.
4. 未经本中心书面同意, 不得将此报告用于商业性及不当宣传。The report may not be used for commercial and inappropriate publicity without the written consent of the center.
5. 未加盖资质认定标志或认证认可标志的报告, 不具有对社会的证明作用, 仅作为科研、教学或内部质量控制之用。The report without qualification certification logo shall have no function of proof to the society, and may be only used for scientific research, teaching or internal quality control.

TR-09-705B

烟台海关技术中心
Technology Center of Yantai Customs

检测报告

TESTING REPORT

地址：山东省烟台市高新区科技大道5号

Address: No. 5, Science and Technology Avenue, High-Tech Zone, Yantai, Shandong

邮编 (P.C.): 264000

电话 (Tel): 0535-3064061, 3064062, 3064051

编号: 37030007262100756

日期: 2026-06-26

第 2 页 共 3 页

	度标准)					
2621007560001	钡	54.0	ug/L	GB/T 5750.6-2023 19.3	合格	曹鹏
2621007560001	铝	23.1	ug/L	GB/T 5750.6-2023 4.5	合格	曹鹏
2621007560001	锰	1.01	ug/L	GB/T 5750.6-2023 6.6	合格	曹鹏
2621007560001	四氯乙烯	<1.0	ug/L	GB/T 5750.8-2023(11.2)	合格	曹鹏
2621007560001	六氯丁二烯	<0.1	ug/L	GB/T 5750.8-2023(47.2)	合格	曹鹏
2621007560001	溴酸盐	<5	ug/L	GB/T 5750.10-2023 (22.1)	合格	曹鹏
2621007560001	三氯甲烷	<1.0	ug/L	GB/T 5750.10-2023(4.3)	合格	曹鹏
2621007560001	臭和味	无	-	GB/T 5750.4-2023(6.1)	合格	曹鹏
2621007560001	浑浊度 (散射 浑浊度单位)	<0.5	NTU	GB/T 5750.4-2023(5.1)	合格	曹鹏
2621007560001	总氮	0.1	mg/L	GB/T 5750.11-2023	合格	曹鹏
2621007560001	氯乙烯	<1.0	ug/L	GB/T 5750.8-2023(7.1)	合格	曹鹏
2621007560001	氯化物	38.00	mg/L	GB/T 5750.5-2023 (5.2)	合格	曹鹏
2621007560001	三氯乙酸	<10.0	ug/L	GB/T 5750.10-2023(16.1)	合格	曹鹏
2621007560001	乙草胺	<0.2	ug/L	GB/T 5750.9-2023 (41.1)	合格	曹鹏
2621007560001	草甘膦	<0.15	mg/L	GB/T 5750.9-2023(21.2)	合格	曹鹏
2621007560001	微囊藻毒素 -LR	<0.26	ug/L	GB/T 5750.8-2023(16.2)	合格	曹鹏
2621007560001	二氯乙酸	<10.0	ug/L	GB/T 5750.10-2023(15.1)	合格	曹鹏
2621007560001	硝酸盐 (以 N 计)	9.91	mg/L	GB/T 5750.5-2023 (8.3)	合格	曹鹏
2621007560001	三溴甲烷	5.0	ug/L	GB/T 5750.10-2023(5.2)	合格	曹鹏
2621007560001	溴化菊酯	<1.0	ug/L	GB/T 5750.9-2023(14.1)	合格	曹鹏
2621007560001	苯乙烯	<5.0	ug/L	GB/T 5750.8-2023(38.2)	合格	曹鹏
2621007560001	溶解性总固体	381	mg/L	GB/T 5750.4-2023(11.1)	合格	曹鹏
2621007560001	游离氯	0.1	mg/L	GB/T 5750.11-2023	合格	曹鹏
2621007560001	硼	<0.20	mg/L	GB/T 5750.6-2023(29.1)	合格	曹鹏
2621007560001	敌敌畏	<0.4	ug/L	GB/T 5750.9-2023(17.2)	合格	曹鹏
2621007560001	2,4,6-三氯酚	<0.4	ug/L	GB/T 5750.10-2023(19.3)	合格	曹鹏
2621007560001	肉眼可见物	无	-	GB/T 5750.4-2023(7.1)	合格	曹鹏
2621007560001	氯酸盐	95.7	ug/L	GB/T 5750.10-2023 (21.2)	合格	曹鹏
2621007560001	三氯乙烯	<1.0	ug/L	GB/T 5750.8-2023(10.2)	合格	曹鹏
2621007560001	三氯乙炔总量	<1.0	ug/L	GB/T 5750.8-2023(30.2)	合格	曹鹏
2621007560001	钡	<0.09	ug/L	GB/T 5750.6-2023 15.4	合格	曹鹏
2621007560001	乐果	<0.1	ug/L	GB/T 5750.9-2023(11.1)	合格	曹鹏
2621007560001	钼	0.93	ug/L	GB/T 5750.6-2023 16.3	合格	曹鹏
2621007560001	六氯苯	<0.4	ug/L	GB/T 5750.9-2023(23.2)	合格	曹鹏
2621007560001	苯	<5.0	ug/L	GB/T 5750.8-2023(21.2)	合格	曹鹏
2621007560001	三溴甲烷 (三 氯甲烷、一氯 二溴甲烷、二 氯一溴甲烷、 三溴甲烷的总 和) 各种化合 物的实测浓度	0.66		/	合格	曹鹏

1. 我们已尽所知所能实施上述检验, 不能因签发本报告而免除有关各方根据合同和法律所承担的责任和义务。All inspection are carried out conscientiously to the best of our knowledge and ability. This report does not in any respect absolve the other related parties from his contractual and legal obligation.
2. 一般情况, 检验结果仅对申请人所送样品负责, 未经本实验室书面同意, 不得部分复制报告。The results shown in this test report refer only to the sample(s) tested unless otherwise stated. Without the prior written approval from the testing laboratory, the report shall not be reproduced except in full.
3. 本报告未经报告签发人签字或盖章无效。The report is invalid unless it is signed by the report issuer and with a special stamp for inspection.
4. 未经本中心书面同意, 不得将此报告用于商业性及不当宣传。The report may not be used for commercial and inappropriate publicity without the written consent of the center.
5. 未加盖资质认定标志或认证认可标志的报告, 不具有对社会的证明作用, 仅作为科研、教学或内部质量控制之用。The report without qualification certification logo shall have no function of proof to the society, and may be only used for scientific research, teaching or internal quality control.

TR-09-705B

检测报告

TESTING REPORT

地址：山东省烟台市高新区科技大道5号
Address: No. 5, Science and Technology
Avenue, High-Tech Zone, Yantai, Shandong
邮编 (P.C.): 264000
电话 (Tel): 0535-3064061, 3064062, 3064051

编号: 37030007262100756

日期: 2026-06-26

第 3 页 共 3 页

	与其各自限值的 比值之和					
2621007560001	高锰酸盐指数 (以 O ₂ 计)	1.57	mg/L	GB/T 5750.7-2023(4.1)	合格	曹鹏
2621007560001	二甲苯	<5.0	µg/L	GB/T 5750.8-2023(23.3)	合格	曹鹏
2621007560001	高氯酸盐	<0.005	mg/L	GB/T 5750.5-2023 (14.1)	合格	曹鹏
2621007560001	2-甲基异莰醇	<5.0	ng/L	GB/T 5750.8-2023 (77)	合格	曹鹏
2621007560001	土臭素	<5.0	ng/L	GB/T 5750.8-2023 (76.1)	合格	曹鹏
2621007560001	百菌清	<0.5	µg/L	GB/T 5750.9-2023(12.2)	合格	曹鹏
2621007560001	1,2-二氯乙烯	<20.0	µg/L	GB/T 5750.8-2023(9.3)	合格	曹鹏
2621007560001	马拉硫磷	<0.4	µg/L	GB/T 5750.9-2023 (10.2)	合格	曹鹏
2621007560001	呋喃丹	<0.0005	mg/L	GB/T 5750.9-2023(18.2)	合格	曹鹏
2621007560001	二氯甲烷	<20.0	µg/L	GB/T 5750.8-2023(49.2)	合格	曹鹏
2621007560001	丙烯酰胺	<0.020	µg/L	GB/T 5750.8-2023(13.1)	合格	曹鹏
2621007560001	pH	6.76		GB/T 5750.4-2023(8.1)	合格	曹鹏
2621007560001	氯苯	<5.0	µg/L	GB/T 5750.8-2023(26.2)	合格	曹鹏
2621007560001	二氯一溴甲烷	25.3	µg/L	GB/T 5750.10-2023(6.2)	合格	曹鹏
2621007560001	1,1-二氯乙烯	<10.0	µg/L	GB/T 5750.8-2023(8.3)	合格	曹鹏
2621007560001	阴离子合成洗 涤剂	<0.025	mg/L	GB/T 5750.4-2023(13.2)	合格	曹鹏
2621007560001	毒死蜱	<0.4	µg/L	GB/T 5750.9-2023(19.2)	合格	曹鹏
2621007560001	锑	<0.07	ug/L	GB/T 5750.6-2023 22.3	合格	曹鹏
2621007560001	铍	<0.03	ug/L	GB/T 5750.6-2023 23.4	合格	曹鹏
2621007560001	铊	<0.01	ug/L	GB/T 5750.6-2023 24.2	合格	曹鹏
2621007560001	铟	<0.9	ug/L	GB/T 5750.6-2023 8.4	合格	曹鹏
2621007560001	甲苯	<5.0	µg/L	GB/T 5750.8-2023(22.3)	合格	曹鹏
2621007560001	一氯二溴甲烷	18.6	µg/L	GB/T 5750.10-2023(7.2)	合格	曹鹏
2621007560001	二氧化氯	<0.025	mg/L	GB/T 5750.11-2023(8.1)	合格	曹鹏
2621007560001	镉	<0.06	ug/L	GB/T 5750.6-2023 12.4	合格	曹鹏
2621007560001	四氯化碳	<1.0	µg/L	GB/T 5750.8-2023(4.3)	合格	曹鹏
2621007560001	总 β	<0.03	Bq/L	GB/T 5750.13-2023	—	曲志勇
2621007560001	总 α	<0.02	Bq/L	GB/T 5750.13-2023	—	曲志勇

备注:

判定依据: GB 5749-2022 生活饮用水卫生标准

检验结

论: 经检验, 所检项目符合 GB 5749-2022 标准要求。

签发人: 曲志勇



1. 我们已尽所知所能实施上述检验, 不能因签发本报告而免除有关各方面根据合同和法律所承担的责任和义务。All inspection are carried out conscientiously to the best of our knowledge and ability. This report does not in any respect absolve the other related parties from his contractual and legal obligation.
2. 一般情况, 检验结果仅对申请人所送样品负责, 未经本实验室书面同意, 不得部分复制报告。The results shown in this test report refer only to the sample(s) tested unless otherwise stated. Without the prior written approval from the testing laboratory, the report shall not be reproduced except in full.
3. 本报告未经报告签发人签字或盖章无效。The report is invalid unless it is signed by the report issuer and with a special stamp for inspection.
4. 未经本中心书面同意, 不得将此报告用于商业性及不当宣传。The report may not be used for commercial and inappropriate publicity without the written consent of the center.
5. 未加盖资质认定标志或认证认可标志的报告, 不具有对社会的证明作用, 仅作为科研、教学或内部质量控制之用。The report without qualification certification logo shall have no function of proof to the society, and may be only used for scientific research, teaching or internal quality control.

TR-09-705B